

# PAROC XMV, Water vapour control layer

Holder/Issued to

## PAROC AB

PAROC AB, 541 86 SKÖVDE, Sweden

Organisation number: 556036-3763

Phone: +46 (0)500-46 90 00, Fax: +46 (0)500-46 94 80

E-mail: [paroc.se@paroc.com](mailto:paroc.se@paroc.com) , Web: [www.paroc.se](http://www.paroc.se)

### Product description

Water vapour control layer made of LD-Polyethylene, with a nominal thickness of 0,12 mm, 0,15 mm or 0,20 mm.

### Intended use

Water vapour control layer, to be used in buildings, in walls, inner ceilings and floors.

### Trade name

PAROC XMV 012, PAROC XMV 012 zcf, PAROC XMV 015, PAROC XMV 015 zcf, PAROC XMV 020 and PAROC XMV 020 zcf.

Trade name with the addition "zcf" refers to a folded version of the product.

### Approval

The products have been found to meet the requirements in the following sections of Boverket's Building Regulations (BBR) issued by the National Board of Housing, Building and Planning.

#### BBR

Moisture, General

6:51

Moisture safety, Air tightness

6:531

Moisture safety, Roofs and attic spaces

6:5325, second general recommendation, fourth and fifth sentence

#### PBL

Energy management and thermal insulation

Chap. 8, 4§ section 6

The products have been assessed against Certification rule CR128 appendix 1, Water vapour control layer.

### Associated documents

"Arbetsanvisning XMV 012 015 020" dated 170825, sections concerning water vapour control layer.

### Control

The factory production control (FPC) is monitored by an independent inspection body.

Control agreement: 410-94-0463, Inspection body: RISE Research Institutes of Sweden.

When the building proprietor performs inspection at the building site, markings shall be checked to ensure that the correct products have been supplied and that they are used in accordance with the conditions in this approval and associated documents.

Certificate no. 0278-08 | 2017-09-28

RISE Research Institutes of Sweden AB | Certification  
Box 857, SE-501 15 Borås, Sverige  
Tel: +46 10-516 50 00  
certifiering@ri.se | www.ri.se

2017-09-28



6P05831



### Manufacturing place

Production control includes the following place:  
AB Raniplast Oy, FI-687 00, Terjärv

### Marking

The products are to be marked at the factory. The marking consists of a text on every packing supplied and includes:

#### Marking onto the product:

Product type designation

P-mark

Certificate number

Consecutive manufacture No./date of production

Property

PAROC XMV Luft- och ångspärr  
0,12 mm, 0,15 mm alt. 0,20 mm

P

0278/08

no./date

Luft- och ångspärr

#### Marking on the packaging:

Approval holder

Manufacturing site

P-mark

Certification body

Product type designation

Certificate number

Properties, Water vapour resistance

Property, length and width

Inspection body

PAROC AB

Terjärv

P

RISE Certifiering

PAROC XMV Luft- och ångspärr

0,12 mm, 0,15 mm or 0,20 mm

0278/08

Value

Value, Value

RISE

### Basis for judgement/approval

Reports FX106722B, 6F008564B and 7F007103A from SP Sveriges Tekniska Forskningsinstitut.

### Comments

The product shall have a packing that prevents it from being exposed to UV-radiation during outdoor storage.

Installation instructions (e.g. Associated documents) shall accompany every delivery to the installation site and be accessible at installation and inspection.

This approval supersedes the previous approval with the same number dated 2009-04-16, valid through 2014-04-15.

### Validity

Valid through 2022-09-27.

Linda Ring Thorén

Susanne Andersson

*This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish text shall take precedence.*